

Chan, Janice

From: Shari Yeatts <syatts@hickmanseggs.com>
Sent: Monday, March 14, 2016 2:18 PM
To: Shannon Klimek - AQDX; Frank Ruiz; Bryan Mandalfino - AQDX
Subject: RE: 040136 Reinspection 14mar2016

Follow Up Flag: Follow up
Flag Status: Completed

Thank you Shannon, I'll wait for official letter before responding with any questions.

Shari
623-692-8451

----- Original message -----

From: Shannon Klimek - AQDX <Klimeks@mail.maricopa.gov>
Date: 03/14/2016 2:11 PM (GMT-07:00)
To: Shari Yeatts <syatts@hickmanseggs.com>, Frank Ruiz <fruiz@hickmanseggs.com>, Bryan Mandalfino - AQDX <BryanMandalfino@mail.maricopa.gov>
Subject: 040136 Reinspection 14mar2016

Summary:

I will be more specific in an email later (I have no access to Outlook right now).
: pending records of generator maintenance for 2015.
: will rescind vent violation of CFR as vent is for outer wall of double walled tank only
: potential additional violations for installing generators G-4; and G-43
prior to being permitted.
(I will follow up with you upon further review in office.

I will be pleased to hear from you if you have questions.

Sincerely,
Shannon Klimek
602.527.6288

Sent from my iPhone